

**FORM - D**

Form of Licence Under Sub-Section (i) of the section 6 of the Tamil Nadu Public Building (Licensing) Act 1965 (Tamil Nadu Act 13 of 1965) referred to in Rule 6 of the Tamil Nadu Public Buildings (Licensing) Rules (1) 1966.

LICENCE

Licence No. 156/2018

 Fee Rs.5000/-Remitted in
 Chalan No.00017
 Dated: 23.03.2018.
 at SBI, Gobi

Licence is hereby granted to **The Principal, MONTFORT SCHOOL, R.S.F.No. 50/3B, D.G.Pudur, Periyakodiveri Village & Town Panchayat, Gobichettipalayam Taluk, Erode District** for the purpose and in respect of the building specified in the statement below and subject to the condition and for the period mentioned hereunder:-

The period of validity of the licence shall be From

01.06.2018 TO 31.05.2021

STATEMENT TO ACCOMPANY THE LICENCE

| Location of the Building (door No. street No, and name of the place) | Purpose for which the building is licenced to be used as a public building | Number of Students to be accommodated |
|---|--|---------------------------------------|
| The Principal, MONTFORT SCHOOL, R.S.F.No. 50/3B, D.G.Pudur, Periyakodiveri Village & Town Panchayat, Gobichettipalayam Taluk, Erode District. | To Run a School | 1500 Students |



[Signature]
 21/4/18
 TAHSILDAR,
 GOBICHETTIPALAYAM.

The Principal,
 MONTFORT SCHOOL,
 R.S.F.No. 50/3B,
 D.G.Pudur,
 Periyakodiveri Village & Town Panchayat,
 Gobichettipalayam Taluk,
 Erode District.

[Signature]
 PRINCIPAL & CORRESPONDENT
 MONTFORT SCHOOL
 D.G.Pudur, Gobi, Erode.
 Tamilnadu - 638 503.

Lion. Er. K.S.KANDASAMY B.E., M.I.E., F.I.V.,
Assistant Executive Engineer - P.W.D. (Rtd)
Chartered Civil Engineer
Approved Valuer
Licenced Building Surveyor

Office : SRI SWATHY ENGINEERING CONSULTANTS & VALUERS
70, 71, Sri Valli Theatre Road, Gobichettipalayam. Ph : 224808
Resi : 16, C.K.S. Nagar, Sathy Road, Gobichettipalayam. Ph : 221722

Chartered Engineer
Registration No. M/122907/3

★

Registered Valuer for
Income Tax Department,
Ministry of Finance,
Govt. of India.
CL/2002-03/CCIT/CBE

★

Approved Valuer
Registration No. F. 10964

★

Licensed Building Surveyor
for Gobi Municipality

★

Panel Valuer for
L.I.C. Housing Finance Ltd.,
Registration No. E - 72/2002

★

Panel Valuer for
Nationalised Banks

1. State Bank of India
2. UCO Bank
3. City Union Bank
4. Bank of India
5. TIFC
6. Repco Bank
7. Corporation Bank
8. Karur Vysya Bank
9. DENA Bank
10. Ujjivan Financial P. Ltd.,

★

Panel Engineer - Class IA,
for issue of stability
certificates for Public,
Buildings like Schools,
Kalyana Mandapams,
Cinema Theatres,
Hospitals etc.,
for Value upto and above
Rs. 30.00 Lakhs.

★

Date :

19.03.2018

Certified that I have inspected the Compound wall of " MONTFORT SCHOOL" in S.F.No.50/3B, D.G.Pudhur, Periyakodivery village & Town Panchayat, Gobichettipalayam Taluk, Erode District, I have personally verified checked & measured the Compound wall of the School which is structurally Sound. This certificate is for the Compound wall with 2 Gates. There is no Structure / Building in this Compound, Which is used or unused unsafe for Children. This certificate do not be valued if any addition / alteration works done subsequently.

K.S.Kandasamy
19-3-18

ENGINEER

Er.K.S.KANDASAMY B.E., M.I.E., F.I.V.,
Panel Engineer Class 1A,
Collector Erode Dist.
Letter No. R.DIST5369/2005/C2 Dt.18.11.0

Pr. Shiva

PRINCIPAL & CORRESPONDENT
MONTFORT SCHOOL
D.G.Pudur, Gobi, Erode
Tamilnadu - 638 503.

LION. ER. K.S.KANDASAMY B.E., M.I.E., F.I.V.,
 Assistant Executive Engineer - P.W.D. (Rtd)
 Chartered Civil Engineer
 Approved Valuer
 Licensed Building Surveyor

Office : SRI SWATHY ENGINEERING CONSULTANTS & VALUERS
 70, 71, Sri Valli Theatre Road, Gobichettipalayam. Ph : 224868
 Resl : 16, C.K.S. Nagar, Sathy Road, Gobichettipalayam. Ph : 221722

Date :

Chartered Engineer
 Registration No. M/122907/3

Registered Valuer for
 Income Tax Department,
 Ministry of Finance,
 Govt. of India
 CI/2002-03/COIT/CBE

Approved Valuer
 Registration No. F. 10984

Licensed Building Surveyor
 for Gobi Municipality

Panel Valuer for
 L.I.C. Housing Finance Ltd.,
 Registration No. E - 72/2002

Panel Valuer for
 Nationalised Banks
 1. State Bank of India
 2. UCO Bank
 3. City Union Bank
 4. Bank of India
 5. TIC
 6. Repco Bank
 7. Corporation Bank
 8. Karur Vysya Bank
 9. DENA Bank
 10. Ujjivan Financial P. Ltd.,

Panel Engineer - Class IA,
 for issue of stability
 certificates for Public,
 Buildings like Schools,
 Kalyana Mandapams,
 Cinema Theatres,
 Hospitals etc.,
 for Value upto and above
 Rs. 30.00 Lakhs.

MONTFORT SCHOOL
 PERIYAKODIVERY VILLAGE
 GOBICHETTIPALAYAM TALUK

Structural soundness of the 9" thick Brick Compound Wall

- | | | |
|--|---|---|
| 1. Depth below ground level | : | 1.22 m (4'0") |
| 2. Nature of soil met with at Foundation level | : | Hard Gravel |
| 3. Pressure at Foundation | : | 5.73 t/m ² |
| 4. Probable safe bearing capacity of the Strata Met with at Foundation | : | 45.00 t/m ² |
| 5. Maximum stress in the most critical Section of masonry and concrete | : | 4.31 t/m ² |
| 6. Nature of masonry and concrete and Its safe permissible stress | : | 55.00 t/m ² For Brick work in Cement mortar using Chamber Bricks |

W.K. Kandasamy
 Er. K.S. KANDASAMY B.E., M.I.E., F.I.V.,
 Panel Engineer Class 1A,
 Collector Erode Dist.
 Letter No. R.DIS75369/2005/C2 Dt.16.11.04

LION. ER. K.S.KANDASAMY B.E., M.I.E., F.I.V.,
 Assistant Executive Engineer - P.W.D. (Rtd)
 Chartered Civil Engineer
 Approved Valuer
 Licensed Building Surveyor

Office : SRI SWATHY ENGINEERING CONSULTANTS & VALUERS
 70, 71, Sri Valli Theatre Road, Gobichettipalayam. Ph : 224868
 Resl : 16, C.K.S. Nagar, Sathy Road, Gobichettipalayam. Ph : 221722

Date :
 19.03.2018

Chartered Engineer
 Registration No. M/122907/3

Registered Valuer for
 Income Tax Department,
 Ministry of Finance,
 Govt. of India
 CI/2002-03/COIT/CBE

Approved Valuer
 Registration No. F. 10984

Licensed Building Surveyor
 for Gobi Municipality

Panel Valuer for
 L.I.C. Housing Finance Ltd.,
 Registration No. E - 72/2002

Panel Valuer for
 Nationalised Banks
 1. State Bank of India
 2. UCO Bank
 3. City Union Bank
 4. Bank of India
 5. TIC
 6. Repco Bank
 7. Corporation Bank
 8. Karur Vysya Bank
 9. DENA Bank
 10. Ujjivan Financial P. Ltd.,

Panel Engineer - Class IA,
 for issue of stability
 certificates for Public,
 Buildings like Schools,
 Kalyana Mandapams,
 Cinema Theatres,
 Hospitals etc.,
 for Value upto and above
 Rs. 30.00 Lakhs.

CERTIFICATE FOR RAIN WATER HARVESTING PIT

- ❖ This is to certify that I have Personally inspected the premises of "MONTFORT SCHOOL" in S.F.No.30/3B, D.G.Pudhur, Periyakodivery village & Town Panchayat, Gobichettipalayam Taluk, Erode District
- ❖ Rain Water Harvesting Pit of Size 8'0" x 4'0" x 5'0" have been made.
- ❖ The Pit is filled with broken brick jelly of ¾ to 1" size mixed with sand and the pit is covering with Porous Reinforced Cement Concrete Slab.

W.K. Kandasamy
 Er. K.S. KANDASAMY B.E., M.I.E., F.I.V.,
 Panel Engineer Class 1A,
 Collector Erode Dist.
 Letter No. R.DIS75369/2005/C2 Dt.16.11.04

Pr. Shrin
 PRINCIPAL & CORRESPONDENT
 MONTFORT SCHOOL
 D G. Pudur, Gobi, Erode,
 Tamilnadu - 638 503.

DECLARATION

I, **K. S. KANDASAMY**, S/o. **K.N. Senthilal** Counder 16, C.E.S. Nagar, Gobichettipalayam 638 452 do hereby declare that I possess the Qualification and experiences specified in the Table of Rule 11 of the Tamil Nadu Public Building Licensing Act 1965 and the Rules framed there under for issuing the certificate of structural soundness of the Buildings covered by the certificate.

Registration No : AEE/ TJE/78449/02 Dated 4.12.2002
 Erode Collector's R.Dis. No. 75369/2005/02 Dated 16.11.05

Station : Gobichettipalayam.
 Date : 19.03.2018

1. Name and Address : **Er. K.S. KANDASAMY**
 16, C.E.S. NAGAR,
 GOBICHETTIPALAYAM 638 452,
 ERODE DISTRICT.
2. Engineering Qualification : **B.E. [Civil] M.I.E., F.I.V.,**
3. Numbering of Years of Experience and nature thereof : **51 Years in Planning, Designing and Execution for Residential Building, Commercial School & Factory Buildings, etc., and worked in PWD, and retired.**

W.V. 19.3.18
Er. K.S. KANDASAMY B.E., M.I.E., F.I.V.,
 Panel Engineer Class 1A,
 Collector Erode Dist.,
 Letter No. R.DIS 75369/2005/G2 IX.16.11.05

Form B

(Form of certificate of structural soundness under sub-section (4) of section 4 of the Tamilnadu Public Buildings (Licensing) Act, 1965 (TamilNadu Act 13 of 1965), Referred to in rule 4. of the Tamilnadu Public Buildings (Licensing) Rules, 1966)

I certify that I have inspected the Building mentioned in the statement and furnish below its salient technical features:

[1] Foundation:

- | | |
|--|--------------------------|
| (i) Depth below ground level | : 5'0" (1.52 M) |
| (ii) Nature of Soil met with at foundation level | : Hard Gravel |
| (iii) a) Pressure at Foundation - Main Building | : 33.39 t/m ² |
| b) Compound Wall | : 5.73 t/m ² |
| (iv) Probable safe bearing capacity of the strata Met with at Foundation | : 45.00 t/m ² |

[2] Superstructure:

- | | |
|--|--|
| (i) a) Maximum stress in the most critical Section of masonry and concrete | : 27.03 t/m ² |
| b) Compound Wall | : 4.31 t/m ² |
| (ii) Nature of masonry and concrete and Its safe permissible stress | : 55.00 t/m ² for Brick work in Cement Mortar using Chamber bricks. |

The structural of the building has been verified by me with reference to ISI loading standards 875 (latest version) and other relevant Indian Standards Code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A license may be granted for the period from 01.06.2018 to 31.05.2021

Dated: 19.03.2018

W.V. 19.3.18
Er. K.S. KANDASAMY B.E., M.I.E., F.I.V.,
 Panel Engineer Class 1A,
 Collector Erode Dist.,
 Letter No. R.DIS 75369/2005/G2 IX.16.11.05

Erode Collector's R.Dis. No. 75369/2005/02 Dated 16.11.05
 Registration No. AEE/ TJE/78449/02 Dated 4.12.2002
 Class: I - A
 (For Rs. 30.00 lakhs and above)

Pr. Shrin
PRINCIPAL & CORRESPONDENT
MONTFORT SCHOOL
D.G.Pudur, Gobi, Erode,
Tamilnadu - 638 503.

**STATEMENT ACCOMPANYING
THE CERTIFICATE OF STRUCTURAL SOUNDNESS**

1. Location of the building Door number,
Street and Name of the place

i. S.F.No : S.F.No: 50/3B, Sathy - Athanai Main Road,
Periya kodivery village
& Town panchayat
ii. Taluk : Gobichettipalayam Taluk,
iii. District : Erode District.

2. Age of the Building : 7 Years & 5 Years

3. Number of Storey : Ground, First & Second floor only

4. Short description of the Structures, State : R.C.C Framed structure

5. Purpose for which the building is certified for use : Class rooms, Principal Room, Office,
Library, laboratory & Toilet for
MONTFORT SCHOOL, D.G.Pudhur


6. The period for which the building will be
Structurally sound : 93 years depending upon the future
Maintenance

7. Number of persons to be accommodated : 1500 Students

8. Area of Construction : 6224.73 Sq.m (or) 67,004.61 Sq.ft
(As per detailed calculation sheet enclosed as Annexure)

9. Remarks :

Date: 19.03.2018


Er.K.S.KANDASAMY B.E.,M.I.E. (V.)
 Panel Engineer Class 1A,
 Erode Dist.
 Letter No. R.DIS/5369/2005/C2 Dt. 16.11.05

Address : Er. K.S. KANDASAMY
16, C.K.S. Nagar
Gobichettipalayam 638 452.
Erode District.

Erode Collector's R.Dis. No. 75369/2005/02 Dated 16.11.05
Registration No. ABE/ TIJE/78449/02 Dated 4.12.2002
Class: I - A
(For Rs. 30.00 lakhs and above)

FORM 'C'

Form of certificate of structural soundness under sub-section (1) of section 5 of the Tamil Nadu public Buildings (Licensing) Act, 1965 (Tamil Nadu Act 13 of 1965) referred to in rule 5 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966.

I certify that I have inspected the Building mentioned in the statement and furnish below its salient technical features:

[1] Foundation:

(i) Depth below ground level : 5'0" (1.52 M)

(ii) Nature of Soil met with at foundation level : Hard Gravel

(iii) a) Pressure at Foundation - Main Building : 33.39 t/m²
b) Compound Wall : 5.73 t/m²

(v) Probable safe bearing capacity of the strata
Met with at Foundation : 45.00 t/m²


[2] Superstructure:

(i) a) Maximum stress in the most critical
Section of masonry and concrete : 27.03 t/m²
b) Compound Wall : 4.31 t/m²


(ii) Nature of masonry and concrete and
Its safe permissible stress : 55.00 t/m² for Brick work in
Cement Mortar using Chamber bricks.

The structural of the building has been verified by me with reference to ISI loading standards 875 (latest version) and other relevant Indian Standards Code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A license may be granted for the period from 01.06.2018 to 31.05.2021

Dated: 19.03.2018


Er.K.S.KANDASAMY B.E.,M.I.E.,P.I.V.
 Panel Engineer Class 1A,
 Erode Dist.
 Letter No. R.DIS/5369/2005/C2 Dt. 16.11.05

Erode Collector's R.Dis. No. 75369/2005/02 Dated 16.11.05
Registration No. ABE/ TIJE/78449/02 Dated 4.12.2002
Class: I - A
(For Rs. 30.00 lakhs and above)


PRINCIPAL & CORRESPONDENT
MONTFORT SCHOOL
 D.G.Pudur, Gobi, Erode,
 Tamilnadu - 638 503.